

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140090, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	John Borns	Partial	Thursday, May 22, 2014

Corrective Action Required  
2 MISC

IMC 507.16 COMMERCIAL KITCHEN GREASE HOOD PERFORMANCE TEST:  
NEBB-CERTIFIED REPORT REQUIRED TO BE SUBMITTED TO INSPECTOR WHEN  
EQUIPMENT IS OPERATIONAL AND BEFORE COMMERCIAL USE. SMOKE  
CAPTURE TEST TO BE CERTIFIED BY 3RD PARTY OR WITNESSED BY INSPECTOR  
BEFORE ANY USE IS APPROVED.

**Comments: KEITH - REMINDER TO P1 FOR SUBMISSION TO ME PRIOR TO KITCHEN PHASE FINAL.**