

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140038, Building Permit - Commercial  
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mike Copeland	Partial	Thursday, May 22, 2014

Partial Correction		
1	MISC	AREA AT ENROLMENT COMMON AREA APPROVED

<b>Rated Assembly Inspection</b>	Mike Copeland	Partial	Thursday, May 22, 2014
--------------------------------------	---------------	---------	------------------------

Partial Correction		
1	MISC	STAIR SIDE SCREW PATT OK
		SCREW PATTERN EACH SIDE OF WALL FACING BOTTOM OF STAIR WELL APPROVED. PENETRATIONS IN ASSEMBLY SHALL BE LISTED PENETRATIONS.

**Comments:**