

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140310, Building Permit - Commercial
Address: 795 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Khanh Nguyen Codes Commercial		Failed	Tuesday, May 27, 2014

Corrective Action Required

1	MISC	<ul style="list-style-type: none">-FIRE DEPT. APPROVAL REQUIRED-HEALTH DEPT. APPROVAL REQUIRED-WRAP RESTROOM SINK TRAP-INSTALL EM LIGHT IN RESTROOM-INSTALL RESTROOM SIGNAGE-COMPLETE INSTALLATION OF SINK-SUPPORT THE GAS LINE TO WATER HEATER-COMPLETE HOOKUP OF GAS SERVICE. PAINT TO PROTECT GAS SERVICE LINE FROM CORROSION-INSTALL AN APPROVED GREASE RESERVOIR FOR THE HOOD EXHAUST FAN-COMPLETE LABELING SERVICE PANEL BREAKERS-INSTALL MAXIMUM 15 AMP BREAKER FOR ROOFTOP UNIT FOR FREEZER-SUPPORT AND SECURE ELECTRICAL PER CODE AT KITCHEN HOOD-KITCHEN HOOD: COMPLETE KITCHEN HOOD AND TESTING BY FIRE DEPT.;HAVE 3RD PARTY SUBMIT TESTING REPORT FOR THE HOOD SYSTEM. ADJUST SYSTEM TO PERFORM PER CODE
---	------	---

Comments: