

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20121010, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Thursday, May 29, 2014
Final Building Inspection - Commercial	John Borns	Partial	Thursday, May 29, 2014

Corrective Action Required
2 MISC

FIRE COMMAND SYSTEM PARTIALLY APPROVED BY FD -- SUFFICIENT TO ALLOW TEMPORARY OCCUPANCY OF 5TH FLOOR FINISH. ADDITIONAL ASPECTS OF FIRE COMMAND SYSTEM TO BE COMPLETED BEFORE PERMIT CAN BE CLOSED.

Comments: PERMIT RECORD POSTED CURRENT AND PERMIT LEFT OPEN PENDING COMPLETION AND APPROVAL OF FIRE COMMAND SYSTEM.