



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20140543	Date:	May 29, 2014
Project Title:	RUE 21 SUMMIT FAIR	Applicant:	
Location:	950 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086	KCFS	
Type of Work:		901 E LOULA	
Occupancy Group:	M	OLATHE, KS 66061	
Description:	TENANT FINISH	Primary:	<NO PRIMARY PHONE>
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Waterflow and tampers to be labeled and addressed for the Rue 21 space, verified at testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.