

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140543, Building Permit - Commercial
Address: 950 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Partial	Friday, May 30, 2014

Partial Correction	
1 MISC	BATHROOM LIDS APPROVED

Comments: