

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140442, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, Unit:300, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, June 03, 2014

Corrective Action Required
1 MISC

**SMACNA / AIR DIFUSSION COUNCIL / MANUFACTURER'S INSTRUCTIONS >
INSTALLATION OF HVAC FLEXIBLE DUCT OR CONNECTORS: CLAMPS &
TAPING OF INNER AND OUTER LAYER MUST BE PER INSTRUCTIONS.
NON-METALLIC CLAMPS OK ONLY WITH BEADED FITTINGS. LEAVE TILE OUT
AT EACH LOCATION WHERE FLEX DUCT OR CONNECTORS ARE INSTALLED.
REMOVE ANY ABANDONED FLEX AND CAP HARD PIPE.**

Comments: