

Temporary Certificate of Occupancy

Permit #: PRRES20131167
Address: 622 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081622 NW WILLOW
DR, Unit:C, LEES SUMMIT, MO 64081622 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081
Inspected On: Friday, June 06, 2014
Inspected By: John Borns
Expiration Date: 6/19/2014 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Borns	Temporary C of O	Friday, June 06, 2014

Corrective Action Required:

4	MISC	PROVIDE WELL STRUCTURE WHERE GAS PRESSURE REGULATORS AND SHUT-OFF VALVES ARE BELOW GRADE AT UNITS "B" AND "C".
---	------	---