PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140543, Building Permit - Commercial Address: 950 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

In-wall Inspection John Borns Partial Monday, June 09, 2014

Corrective Action Required

1 MISC TWO ROOF DRAIN RISERS AT NORTH WALL: LOCATE TO ACCOMODATE

REMOVAL OF THREADED PLUGS

Rated Assembly John Borns Passed Monday, June 09, 2014

Inspection

Comments: OK TO TAPE & MUD GWB WALLS INCLUDING THE "A" AND "A1" WALLS.