

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140507, Building Permit - Commercial

Address: 1302 SW JEFFERSON ST, LEES SUMMIT, MO 640811304 SW JEFFERSON ST, LEES SUMMIT, MO 640811306 SW JEFFERSON ST, LEES SUMMIT, MO 64081400 SW PERSELS RD, LEES SUMMIT, MO 640811308 SW JEFFERSON ST, LEES SUMMIT, MO 64081302 SW PERSELS RD, LEES SUMMIT, MO 64081320 SW PERSELS RD, LEES SUMMIT, MO 64081304 SW PERSELS RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Mark Harding	Partial	Monday, June 09, 2014

Corrective Action Required

1	MISC	UNDERGROUND CONDUIT- EAST FRONT OF BUILDING- ONLY EAST SIDE LAST 3 POLE LIGHTS NEXT TO JEFFERSON REMAIN
---	------	---

Corrective Action Required

2	MISC	LIGHT POLE BASE INSEPTION-INSPECTED 1-4,5-8, 9-12,13-16,17-20,21-2425-28,29-30 POLE 31 IS UNDER TRAILER AND WILL BE AT A LATER DATE.. 30 POLE LIGHT BASE HAVE BEEN INSEPECTED. 6-9-14MH
---	------	---

Comments: