

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140191, Building Permit - Commercial
Address: 901 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, June 10, 2014

Partial Correction
2 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING
SYSTEMS @ FOLLOWING SPACES: EAST EXPANSION AREA EXCEPT @ NW
CORNER WHERE EXISTING PVC ROOF DRAIN IS PRESENT IN ABOVE-CEILING
PLENUM

**Comments: LEAVE OUT ONE TILE ADJACENT TO EACH DIFFUSER LOCATION AND HAVE LADDER
AVAILABLE FOR INSPECTION OF FLEX CONNECTION NOT PRESENTLY COMPLETED.**