

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20141506, Building Permit - Residential
Address: 901 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Partial	Wednesday, June 11, 2014

Partial Correction
1 MISC

NOISSUES FOUND ON VISUAL INSPECTION OF MC CABLE, BOXES, AND
RECEPTACLES TO POINT OF SERVICE. WORK IS COMPLETED AND CLOSED;
ASSUMED TO BE TEMPORARY. IF TO BE PERMANENT FURTHER INSPECTION
AND IMPROVEMENTS WILL BE REQUIRED.

Comments: