

## FIRE DEPARTMENT

## **PLANS REVIEW CONDITIONS**

Permit No: PRCOM20141292

Project Title: KANSAS CITY SALT MINE Location: 3680 NE AKIN DR, Unit:112,

LEES SUMMIT, MO 64064

Type of Work:

Occupancy Group: B

Description: TENANT FINISH FOR

MASSAGE THERAPY

Construction Type: Type IIB (Unprotected)

Map Page: 175H

Date: June 13, 2014

Applicant:

ALPHA FIRE PROTECTION 1510 WEST GEOSPACE DRIVE INDEPENDENCE, MO 64056--1783

Primary: (816) 257-2260

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review Reviewed By: Brian Austerman Released for Construction

- 1. Maintain a minimum of a 4" spacing from sprinkler hear to wall in corridor
- 2. If there is an isolation valve for the space is shall be maked accordingly

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.