



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20141554	Date:	June 16, 2014
Project Title:	LUMBER WAREHOUSE FIRE SUPPRESSION	Applicant:	
Location:	221 NW CHIPMAN RD, LEES SUMMIT, MO 64063	AEGIS FIRE PROTECTION	
Type of Work:		11936 W. 119th Street	
Occupancy Group:		OVERLAND PARK, KS 66213-	
Description:	INSTALLATION OF NEW FIRE SUPPRESSION SPRINKLER AND ALARM SYSTEMS	Primary: (913) 825-0343	
Construction Type:	Not Applicable		
Map Page:	195B		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Rejected

1. Replace heat detector over FACP with a smoke detector
2. Show outside horn strobe on plans. Place over FDC, and shall activate on waterflow only

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.