

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140090, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Monday, June 16, 2014

Partial Correction
1 MISC

OK TO MOVE IN AND USE PHASE 1 AREA EXCEPT GREASE HOOD. INSTALLATION / RELOCATION OF SOME KITCHEN EQUIPMENT IS ON-GOING; BUILDING AND M/E/P SYSTEMS OK TO RECEIVE EQUIPMENT AND OPERATE EXCEPT EMERGENCY SYSTEMS AT GREASE HOOD YET TO BE APPROVED BY FIRE DEPT.

Alternate Protection Systems Inspection	Joe Dir	Failed	Monday, June 16, 2014
--	---------	--------	-----------------------

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Monday, June 16, 2014
------------------------------------	---------	------------------	-----------------------

Corrective Action Required
1 MISC

- identify all hoods and pull stations
- hood-3 pass the trip test
- in-service tag for hood-3

Comments: