

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141292, Building Permit - Commercial
Address: 3680 NE AKIN DR, Unit:112, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Partial	Thursday, June 19, 2014

Corrective Action Required

1	MISC	-WET VENT IS FOR THE BATH GROUP ONLY, NOT FOR BOTH RESTROOM AND BREAK RM SINK -INSTALL BACKINGS FOR GRAB BARS
---	------	---

****OK TO ROCK EXCEPT THE RESTROOM WALL**

Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Passed	Thursday, June 19, 2014
---	--------------	--------	-------------------------

Electrical Service Inspection - Commercial	Khanh Nguyen	Passed	Thursday, June 19, 2014
---	--------------	--------	-------------------------

Comments: