

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140191, Building Permit - Commercial
Address: 901 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Thursday, June 19, 2014

Partial Correction
1 MISC

CHECK ALL ELECTRICAL RECEPTACLES; ENSURE NONE ARE "SOFT" OR LOOSE SIDE-TO-SIDE.

Partial Correction
2 MISC

RESOLVE FIRE DEPT ISSUES

Partial Correction
3 MISC

SUBJECT TO REVIEW OF PERMIT DRAWINGS NOT ON SITE, OK TO MOVE MERCHANDISE INTO EAST EXPANSION SPACE; BUT DO NOT OBSTRUCT ELECTRICAL RECEPTACLES UNTIL THEY ARE APPROVED.

Comments: