

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140543, Building Permit - Commercial  
Address: 950 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	John Borns	Partial	Friday, June 20, 2014

Partial Correction  
1 MISC

SERVICE EQUIPMENT AND WIRING COMPLETE TO LOAD SIDE DISCONNECT. #6  
SERVICE GROUND TO BUILDING GROUND GRID TO BE REPLACED WITH #4.  
SERVICE RELEASED TO KCP&L FOR SCHEDULING. JB TO RE-INSPECT  
EQUIPMENT AND WIRING PRIOR TO ACTIVATION.

**Comments:**