

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20140593, Building Permit - Residential
Address: 305 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	John Borns	Not Ready	Monday, June 23, 2014

Corrective Action Required

1 MISC

NO RE-BAR IN PLACE; DISCUSSED REQUIREMENTS.

Corrective Action Required

2 MISC

FOOTING ALREADY POURED WITHOUT INSPECTION.

Comments: