

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140591, Building Permit - Commercial
Address: 301 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Passed	Tuesday, June 24, 2014

**Comments: ENSURE 3" MINIMUM COVERAGE OF RE-BAR AT TRENCH BOTTOMS AND BANKS. OK TO
POUR GRADE BEAMS WHEN READY.**