

# Temporary Certificate of Occupancy

---

Permit #: PRRES20131167  
Address: 622 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081622 NW WILLOW  
DR, Unit:C, LEES SUMMIT, MO 64081622 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081  
Inspected On: Tuesday, June 24, 2014  
Inspected By: John Borns  
Expiration Date: 7/10/2014 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	John Borns	Temporary C of O	Tuesday, June 24, 2014

Corrective Action Required:

1	MISC	TCO REINSTATED THROUGH 7/10/14 TO ACCOMODATE PROVISION OF WELL STRUCTURE WHERE GAS PRESSURE REGULATORS AND SHUT-OFF VALVES ARE BELOW GRADE AT UNITS "B" AND "C".
---	------	--