



**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20141554	Date:	June 24, 2014
Project Title:	LUMBER WAREHOUSE FIRE SUPPRESSION	Applicant:	
Location:	221 NW CHIPMAN RD, LEES SUMMIT, MO 64063	AEGIS FIRE PROTECTION	
Type of Work:		11936 W. 119th Street	
Occupancy Group:		OVERLAND PARK, KS 66213-	
Description:	INSTALLATION OF NEW FIRE SUPPRESSION SPRINKLER AND ALARM SYSTEMS	Primary: (913) 825-0343	
Construction Type:	Not Applicable		
Map Page:	195B		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review                      Reviewed By: Brian Austerman                      Rejected**

1. Replace heat detector over FACP with a smoke detector
2. Show outside horn strobe on plans. Place over FDC, and shall activate on waterflow only

**Alarm Plan Review                      Reviewed By: Brian Austerman                      Released for Construction**

1. Replace heat detector over FACP with a smoke detector

Resolved

2. Show outside horn strobe on plans. Place over FDC, and shall activate on waterflow only

Resolved

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**