

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140543, Building Permit - Commercial
Address: 950 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Not Ready	Friday, June 27, 2014

Partial Correction

2 MISC

OK TO SET UP FOR BUSINESS AT SALES AREA ONLY. NO PUBLIC NOR CUSTOMERS PRIOR TO APPROVAL.

Corrective Action Required

3 MISC

RESOLVE FIRE DEPARTMENT ISSUES

Corrective Action Required

4 MISC

NEC 380-10 SECURING OF ELECTRICAL RECEPTACLES / SWITCHES: CHECK ALL AND ENSURE NONE ARE "SOFT" OR LOOSE SIDE-TO-SIDE.

Corrective Action Required

5 MISC

AREAS OTHER THAN SALES AREA NOT READY FOR INSPECTION.

Corrective Action Required

6 MISC

ROOFTOP INSPECTION YET TO BE PERFORMED.

Comments: