

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRRES20141418, Building Permit - Residential  
Address: 1312 NE ERNEST WAY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection - Residential</b>	Khanh Nguyen	Passed	Thursday, July 03, 2014

<b>Underslab Plumbing Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, July 03, 2014
--	--------------	--------	-------------------------

Corrective Action Required  
1 MISC

-THE SHOWER TRAP WEIR TO WET-VENTED DRAIN SHALL BE NO MORE  
THAN 8 FT FOR THE 2" SHOWER DRAIN  
-CONNECT THE FLOOR DRAIN TILES TO SUMP PUMP PIT

<b>Sewer Service Inspection - Residential</b>	Khanh Nguyen	Passed	Thursday, July 03, 2014
---	--------------	--------	-------------------------

Comments: