

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141168, Building Permit - Commercial

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, July 07, 2014

Partial Correction

1 MISC

OK TO COVER WHEN READY SERVICE "A" 1-1/2" BURIED FEEDER CONDUIT FROM METER LOCATION TO TRAILER ENTRY;

Comments: