

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20141418, Building Permit - Residential
Address: 1312 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed	Monday, July 07, 2014

Corrective Action Required
1 MISC

****CLEAN THE STREET AND INSTALL EROSION CONTROL**
****THE FLOOR ALREADY POURED WITH CONCRETE WITHOUT APPROVAL****

-THE SHOWER TRAP WEIR TO WET-VENTED DRAIN SHALL BE NO MORE THAN 8 FT FOR THE 2" SHOWER DRAIN
-CONNECT THE FLOOR DRAIN TILES TO SUMP PUMP PIT

Comments: