

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140191, Building Permit - Commercial  
Address: 901 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Tuesday, July 08, 2014

Partial Correction  
1 MISC

AT NEW STORAGE ROOM WALLS OK TO HANG GWB EXCEPT AT HVAC DUCT PENETRATIONS OF WALL. A/E TO CONSULT WITH LS CODES PLAN REVIEW TO DETERMINE WHETHER DAMPERS ARE REQUIRED -- AND TYPE. WRITTEN RESOLUTION REQUIRED.

**Comments:**