

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141506, Building Permit - Commercial
Address: 901 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Residential	John Borns	Passed	Thursday, July 10, 2014
Rough Electrical Inspection - Commercial	John Borns	Passed	Thursday, July 10, 2014

**Comments: APPROVED CONTINGENT ON JUNCTION BOX ABOVE CEILING BEING SECURED TO
STRUCTURE RATHER THAN TO CEILING SUPPORT WIRE.**