

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20130852, Building Permit - Commercial  
Address: 611 SW 3RD ST, Unit:B, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Failed	Thursday, July 10, 2014

Partial Correction

1 MISC

PER M. COPELAND UPPER LEVEL OK FOR USE.

Corrective Action Required

2 MISC

TWO NEW ROOMS AT LOWER LEVEL: ALL ELECTRICAL RECEPTACLES DISPLAY HOT-NEUTRAL REVERSE. CORRECT AND REQUEST RE-INSPECTION BEFORE ANY USE OF MIS-WIRED RECEPTACLES. ALSO CHECK ALL RECEPTACLES TO ENSURE ALL ARE SOLID TO BOX -- NONE LOOSE SIDE-TO-SIDE NOR "SOFT".

**Comments:**