

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140191, Building Permit - Commercial
Address: 901 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, July 15, 2014

Partial Correction
1 MISC

NEW UL419 WALLS OF DELIVERY SPACE:
- NORTH WALL OK TO TAPE, MUD, AND FIRE-SEAL BOTH FACES
- EAST WALL EAST FACE OK TO TAPE, MUD, AND FIRE-SEAL FULL HEIGHT TO DECK; WEST FACE OK TO TAPE, MUD, AND FIRE-SEAL TO CEILING ELEVATION

Comments: