

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141986, Building Permit - Commercial
Address: 90 NW TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Thursday, July 24, 2014
Final Electrical Inspection - Commercial	John Borns	Passed	Thursday, July 24, 2014

**Comments: PEDESTAL-MOUNTED 100 AMP ELECTRICAL SERVICE INSTALLATION OK
AFTER ONE UNUSED BREAKER OPENING IS PROPERLY BLANKED-OFF. RELEASE
SERVICE. CLOSE PERMIT.**