

Temporary Certificate of Occupancy

Permit #: PRCOM20141969
Address: 676 SE BAYBERRY LN, Unit:103, LEES SUMMIT, MO 64063
Inspected On: Thursday, July 24, 2014
Inspected By: Mike CopelandJoe Dir
Expiration Date: 7/31/2014 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Temporary C of O	Thursday, July 24, 2014

Corrective Action Required:

1	MISC	INSTALL ADDRESS NUMBERS ON DOOR AND EXTERIOR LIGHT FIXTURE
---	------	--

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Thursday, July 24, 2014
------------------------------------	---------	------------------	-------------------------

Corrective Action Required:

1	MISC	<ul style="list-style-type: none">- relpace the keyed cylinder deadblot lock with a rhumb throw lock (rear door)- post the numeric address of the suite 103 on the exterior of the rear door.- install a light fixture or close the j-box beside the rear door (exterior)- mount the fire extinguisher on a wall closwe to an exit
---	------	---

