



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20140977	Date:	July 28, 2014
Project Title:	FRONTIER JUSTICE	Applicant:	
Location:	800 NE JONES INDUSTRIAL DR, LEES SUMMIT, MO 64064	KANSAS CITY FIRE AND SECURITY LLC	
Type of Work:		901 E LOULA ST	
Occupancy Group:	MIX	OLATHE, KS 66061	
Description:	NEW BUILDING - FIRING RANGE AND RETAIL STORE	Primary: (913) 780-5237	
Construction Type:	Type IIB (Unprotected)		
Map Page:	175R		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Per phone conversation with Micah Pruett on 7-17-14 the heat detectors in the archery range will be changed to smoke detectors
2. Outside horn strobe not shown on plans. This is to be located over the FDC and shall activate only on a waterflow alarm.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.