

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140191, Building Permit - Commercial
Address: 901 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Monday, July 28, 2014

Partial Correction
1 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: EAST EXPANSION AREA; NEW STORAGE ROOM RATED WALL APPROVED BOTH FACES, BUT FULL ABOVE-CEILING INSPECTION YET TO BE PERFORMED

Above Ceiling Inspection	John Borns	Partial	Monday, July 28, 2014
---------------------------------	------------	---------	-----------------------

Partial Correction
1 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: EAST EXPANSION AREA; **NEW STORAGE ROOM RATED WALL APPROVED BOTH FACES. HVAC FLEX DUCT NOT SUPPORTED TO ROOF STRUCTURE. SUPPORT PER SMACNA/AIR DIFFUSION COUNCIL STANDARDS.**

Comments: