

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20122454, Building Permit - Commercial  
Address: 312 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:                              | Inspector: | Outcome:  | Date:                  |
|--|------------|---|------------------------|
| <b>All Rough Inspection - Commercial</b> | John Borns | Partial   | Tuesday, July 29, 2014 |
| Partial Correction<br>1 MISC             |            | PROGRESS INSPECTION OF PLUMBING AND ELECTRICAL W/I/P AT CRAWL SPACE AND ATTIC.  |                        |
| Partial Correction<br>2 MISC             |            | OK TO COVER WHEN READY MODIFIED WALL & CEILING FRAMING AND CONTAINED SYSTEMS AT FOLLOWING LOCATIONS: 201; 203; 205; 207; 209; LOUNGE; <b>200; 202; 204; 206; 208; 210</b> |                        |
| <b>Footing Inspection - Commercial</b>   | John Borns | Passed  | Tuesday, July 29, 2014 |

**Comments: OK TO POUR CONCRETE FOOTINGS AT MONUMENT SIGN AND TRASH ENCLOSURE WALLS AFTER PROVIDING 3" MINIMUM CLEARANCE OF RE-BAR AT BOTTOMS AND BANKS.**