

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20130422, Building Permit - Commercial
Address: 3360 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Wednesday, July 30, 2014

Corrective Action Required
1 MISC

3RD FLOOR ONLY:
-GYPSUM TYPE X INSTALLED AT SHOWER WALL-OK

STAIR WELLS ONLY PRIOR TO ROCK:
-PROTECT ALL PLUMBING
-NAIL CORNER STUDS 16D @ 12" OC OR EQUIVALENT NAILING

Comments: