

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132419, Building Permit - Commercial
Address: 2225 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Friday, August 01, 2014

Corrective Action Required

1 Misc 1

UNDERGROUND ELECTRICAL OK BELOW:

- SECONDARY FROM TRANSFORMER TO SERVICE LOCATION
- LIGHT POLE CIRCUITS PLACEMENT- OK AT BACK PARKING LOT
- LIGHT POLE PIERS-10 PIERS AT NORTHERN SECTION OF REAR PARKING LOT

Comments: