

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122454, Building Permit - Commercial
Address: 312 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Tuesday, August 05, 2014

Partial Correction
1 Misc 1

PROGRESS INSPECTION OF PLUMBING AND ELECTRICAL W/I/P AT:
ATTIC: 8/4/14 - NO ISSUES FOUND
CRAWL SPACE: 1) ENGINEER REPORT REQUIRED REGARDING CONDITION OF ELECTRICAL FEEDER CONDUIT RUN ACROSS CRAWL SPACE ON CRUSHED ROCK. APPARENT SIGNIFICANT DETRIORATION DUE TO OXIDATION ON LOWER SURFACE. 2) COLD WATER LINE APPEARS TO LACK SUPPORT OVER PART OF ITS LENGTH.

Comments: