

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140591, Building Permit - Commercial
Address: 301 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Not Ready	Wednesday, August 06, 2014

Corrective Action Required

1	Misc 1	LIGHT FIXTURES NOT COMPLETED AT EXTERIOR SOFFIT.
---	--------	--

Corrective Action Required

2	Misc 1	F.P. SPRINKLER WORK IN PROGRESS ABOVE CEILING.
---	--------	--

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Wednesday, August 06, 2014
--	---------	------------------	----------------------------

Corrective Action Required

1	Misc 1	- add additional sprinkler system coverage in the front foyer(s) vestibule(s) - post the numeric address of 301 on the exterior
---	--------	--

Comments: