

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132419, Building Permit - Commercial
Address: 2225 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Khanh Nguyen	Passed	Thursday, August 07, 2014

In-wall Inspection	Khanh Nguyen	Partial	Thursday, August 07, 2014
---------------------------	--------------	---------	---------------------------

Corrective Action Required

1 Misc 1

IN-WALL OK BELOW:

-WALL AND CEILING SPACE UNDER MEZZANINE AND UPPER MEZZANINE FLOOR

IN-WALL 2ND FL OF ADDITION: FIREBLOCK ALL FLOOR PENETRATIONS;
SECURE MC CABLES AT DRINKING FOUNTAIN AND HOME RUN ON NORTH
CORRIDOR WALL; PROTECT PLUMBING AT DRINKING FOUNTAIN

Comments: