

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140913, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, Unit:245, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Wednesday, August 13, 2014

Partial Correction
1 Misc 1

OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING
SYSTEMS @ FOLLOWING SPACES: SOFFITS AT 217, 226, 227; **SOFFIT OUTSIDE
DOOR 2F200A;**

Comments: