

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122453, Building Permit - Commercial
Address: 310 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Thursday, August 14, 2014

Partial Correction
1 Misc 1

OK TO COVER WHEN READY EXPOSED WALL AND CEILING CAVITIES ALONG
WITH SYSTEMS TO BE CONCEALED AT FOLLOWING **SPACES: 107-114;**

Comments: