

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141292, Building Permit - Commercial  
Address: 3680 NE AKIN DR, Unit:112, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|                                     |              |          |                         |
|-------------------------------------|--------------|----------|-------------------------|
| Inspection:                         | Inspector:   | Outcome: | Date:                   |
| <b>Above Ceiling<br/>Inspection</b> | Khanh Nguyen | Partial  | Friday, August 15, 2014 |

Corrective Action Required  
1 Misc 1

-SEAL DUCT JOINTS AT MAIN DUCT & COMPLETE BATH EXHAUST TO  
OUTSIDE  
-INDEPENDENT SUPPORT WIRE FOR THE MC CABLE MUST BE: SECURED AT  
BOTH END AND COLOR-ID

**Comments:**