

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20131165, Building Permit - Residential

Address: 602 NW REDBUD DR, Unit:B, LEES SUMMIT, MO 64081602 NW REDBUD DR, Unit:C, LEES SUMMIT, MO 64081602 NW REDBUD DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	John Borns	Partial	Tuesday, August 19, 2014

Partial Correction

1 Misc 1

PRESSURE TEST OF GAS FEEDER PIPING TO UNITS:

A: HELD >10 PSI PRESSURE STEADY FOR >10 MIN

B: SHOWING ONLY 2PSI PRESSURE

C: HELD >10 PSI PRESSURE STEADY FOR >10 MIN

Comments: