

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140598, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, Unit:200, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Passed	Wednesday, August 20, 2014

Comments: OK TO COVER WHEN READY LIGHT-GUAGE STEEL WALL FRAMING + IN-WALL SYSTEMS AFTER: 1) ALL JAMB STUDS ARE SCREWED BOTH FLANGES TO BOTTOM TRACK, 2) CRIPPLE STUDS ABOVE DOOR OPENINGS ARE SCREWED BOTH FLANGES TO HEADER TRACK, 3) EXISTING HANGING GWB STRUCTURE PARTIALLY REMOVED IS FASTENED CERTAIN TO "SLIP TRACK" ABOVE.