

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20132440, Building Permit - Commercial  
Address: 101 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - Commercial</b>	John Borns	Passed	Wednesday, August 20, 2014
<b>Water Service Inspection - Commercial</b>	John Borns	Passed	Wednesday, August 20, 2014

**Comments: OK TO COVER WHEN READY SANITARY SEWER SERVICE INSTALLATION FROM BUILDING ENTRY TO CONNECTION AT STUB FROM DEMOLISHED BUILDING -- VARIATION FROM DRAWING APPROVED BY LSPW. WATER SERVICE LINE INSTALLATION FULLY APPROVED PER PERMIT DRAWINGS NOW ON SITE.**