



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

August 20, 2014

CITY OF LEES SUMMIT MO
220 SE GREEN ST
LEES SUMMIT, MO 64081

Permit No: PRCOM20141787
Project Title: CITY HALL PARKS & REC REMODEL
Project Address: 220 SE GREEN ST, LEES SUMMIT, MO 64063
Parcel Number: 61230162300000000
Location: LEES SUMMIT CITY HALL---LOT 1
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: BUSINESS
Description: OFFICE ALTERATIONS - SEPARATING OFFICE SPACE FOR ECONOMIC DEVELOPMENT DEPARTMENT

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review	Reviewed By: Joe Frogge	Approved
Fire Plan Review	Reviewed By: Brian Austerman	Approved
Fire Plan Review	Reviewed By: Brian Austerman	Approved

1. Confirm sprinkler coverage will not be impeded by the addition of the walls. if changes are required provide sprinkler plans

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.