

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20132419, Building Permit - Commercial  
Address: 2225 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - Commercial</b>	Khanh Nguyen	Passed	Thursday, August 21, 2014
<b>Underground Electrical Inspection - Commercial</b>	Khanh Nguyen	Partial	Thursday, August 21, 2014

Corrective Action Required  
1 Misc 1

UNDERGROUND ELECTRICAL OK BELOW:  
-SECONDARY FROM TRANSFORMER TO SERVICE LOCATION  
-LIGHT POLE CIRCUITS PLACEMENT- OK AT BACK PARKING LOT  
-LIGHT POLE PIERS- PIERS AT REAR PARKING LOT OK IN PROGRESS

**Comments:**