

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122453, Building Permit - Commercial
Address: 310 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Friday, August 22, 2014

Partial Correction
1 Misc 1

SYSTEMS IN CRAWL SPACE SUBJECT TO APPROVAL WHEN READY FOR INSPECTION.

Partial Correction
2 Misc 1

SYSTEMS IN ATTIC SUBJECT TO APPROVAL WHEN READY FOR INSPECTION.

Partial Correction
3 Misc 1

OK TO COVER WHEN READY EXPOSED WALL AND CEILING CAVITIES ALONG WITH SYSTEMS TO BE CONCEALED AT FOLLOWING SPACES: 107-114; 101-106; **100 AFTER a) GAPS AT TOPS OF JACK STUDS AT EXTERIOR WALL ARE SHIMMED AND b) SLOPE OF HORIZONTAL PLUMBING VENT ARM IS REVERSED TO DRAIN;**

Comments: