

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20130422, Building Permit - Commercial
Address: 3360 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Failed	Friday, August 22, 2014

Partial Correction
1 Misc 1

2ND & 3RD FLOOR ONLY:
-GYPSUM TYPE X INSTALLED AT SHOWER WALL-OK

SCREW PATTERN OK BELOW:
-STAIR WELLS

Corrective Action Required
2 Misc 1

CEILING FURDOWN FOR DUCTING: INSTALL BOCA PLATES FOR PLUMBING
PROTECTION AT BOTH TOP&BOTTOM WALL PLATES

Comments: